



| | | | CZ 1 | CZ 16 | Comments | |
|------------------------------------|---|--------------------------------------|---|---|--|-----------|
| Insulation^A | Roofs No Radiant Barrier | Opt A No Air Space | No c.i. ^K R-38 ceiling No Rad Barrier | R-8 c.i. R-38 ceiling No Rad Barrier | | |
| | | Opt A With Air Space | No c.i. R-38 ceiling No Rad Barrier | R-6 c.i. R-38 ceiling No Rad Barrier | | |
| | | Opt B ^E No Air Space | No b.r.d. ^K R-38 ceiling No Rad Barrier | R-18 b.r.d. R-38 ceiling No Rad Barrier | | |
| | | Opt B ^E With Air Space | No b.r.d. R-38 ceiling No Rad Barrier | R-13 b.r.d. R-38 ceiling No Rad Barrier | | |
| | | Opt C | No c.i. R-38 ceiling No Rad Barrier Ducts in cond. space | No c.i. R-38 ceiling No Rad Barrier Ducts in cond. space | | |
| | Walls | Above Grade | Framed ^F | U-0.051 | U-0.051 | |
| | | | Mass Wall Interior ^G | U-0.070 R-13 | U-0.059 R-17 | or higher |
| | | | Mass Wall Exterior ^G | U-0.125 R-8 | U-0.070 R-13 | or higher |
| | | Below Grade | Below Grade Interior ^G | U-0.070 R-13 | U-0.066 R-15 | or higher |
| | | | Below Grade Exterior ^G | U-0.200 R-5 | U-0.053 R-19 | or higher |
| | Floors | Slab Perimeter | | NR ^L | U-0.58 R-7 | or higher |
| | | Raised | | U-0.037 R-19 | U-0.037 R-19 | or higher |
| | | Concrete Raised | | U-0.092 R-8 | U-0.092 R-8 | or higher |
| | Roofing Products | Low-sloped | Aged Solar Reflectance | NR | NR | |
| | | | Thermal Emittance | NR | NR | |
| Steep-sloped | | Aged Solar Reflectance | NR | NR | | |
| | | Thermal Emittance | NR | NR | | |
| Fenestration | Maximum U factor ^H | | 0.32 | 0.32 | | |
| | Maximum SHGC ^I | | NR | 0.25 | | |
| | Maximum Total Area | | 20% | 20% | | |
| | Maximum West Facing Area | | NR | 5% | | |
| Space Heating^{B,C} | Electric-Resistance Allowed | | No | No | | |
| | If gas, AFUE | | MIN | MIN | Central furnace <225,000 kBtuh: 80% AFUE or higher ^N | |
| | If Heat Pump, Heating Seasonal Performance Factor (HSPF) | | MIN | MIN | Single-phase air source • Split: <65 kBtuh: 8.2 HSPF or higher ^N • Packaged: <65 kBtuh: 8.0 HSPF or higher ^N | |
| Space Cooling | SEER | | MIN | MIN | Central air conditioner or central air source heat pump | |
| | Refrigerant Charge Verification or Charge Indicator Display | | NR | NR | • Split: <45 kBtuh 14.0 SEER/12.2 EER ≥45 but < 65 kBtuh 14 SEER/11.7 EER | |
| | Whole House Fan ^J | | NR | NR | • Packaged: <65 kBtuh 14 SEER/11 EER or higher ^N | |
| Central System Air Handlers | Central Fan Integrated Ventilation System Fan Efficacy | | REQ | REQ | | |
| Ducts^D | Duct Insulation | | R-6 or R-8 ^M | R-6 or R-8 ^M | or higher | |
| Water Heating | All Buildings | | Gas Storage ≤ 55 gallons; ≤ 105 kBtuh Tankless Instantaneous ≤ 200 kBtuh | | Apr 16, 2015: 0.675-(0.0015*V) ^O EF or higher | |

Notes

- A The U-factors/R-values shown for ceiling, wall and raised floor insulation are for wood-frame construction with insulation installed between the framing members, with continuous insulation where appropriate. For alternative construction assemblies, see [Section 150.1\(c\)1A, B and C](#).
- B A supplemental heating unit may be installed in a space served directly or indirectly by a primary heating system, provided that the unit thermal capacity does not exceed 2 kW or 7,000 Btuh and is controlled by a time-limiting device not exceeding 30 minutes.
- C Furnaces shall have an electrical standby mode power consumption and electrical off mode power consumption not more than the following:
- Non-weatherized gas furnaces (not including mobile home furnaces)..... 10W
 - Non-weatherized oil-fired furnaces (not including mobile home furnaces)..... 11W
 - Electric furnaces 10W
- Central air conditioners and central air conditioning heat pumps manufactured on or after January 1, 2015, shall have an average off mode electrical power consumption of:
- Split-system air conditioners..... 30W
 - Split-system heat pumps..... 33W
 - Single-package air conditioners..... 30W
 - Single-package heat pumps 33W
 - Small-duct, high-velocity systems..... 30W
 - Space-constrained air conditioners..... 30W
 - Space-constrained heat pumps..... 33W
- D Duct sealing is a Mandatory Requirement in all climate zones, as confirmed through field verification and diagnostic testing. See [Section 150.0\(m\)11](#).
- E For Option B, where insulation directly below the roof deck is required, either R-13 insulation between rafters with an air space or R-18 insulation between the rafters with no air space is required.
- F U-factors can be met by cavity insulation alone or with continuous insulation alone, or with both cavity and continuous insulation that results in a U-factor \leq the U-factor shown. Any combination of cavity insulation and/or continuous insulation that results in a U-factor \leq the Prescriptive requirement is allowed.
- G Mass wall has a thermal heat capacity ≥ 7.0 Btuh-ft². Below grade “interior” denotes insulation installed on the inside surface of the wall. Below grade “exterior” denotes insulation installed on the outside surface of the wall.
- H The installed fenestration products shall meet the requirements of [Section 150.1\(c\)3](#).
- I The installed fenestration products shall meet the requirements of [Section 150.1\(c\)4](#).
- J When whole house fans (WHF) are required, only those listed in the [Energy Commission Title 20 Appliance Efficiency Database](#) may be installed. Compliance requires installation of one or more WHFs with total airflow capable of meeting or exceeding a minimum 1.5 cfm/ft² of conditioned floor area per [Section 150.1\(c\)12](#).
- K c.i. = continuous insulation
b.r.d. = below roof deck insulation
- L NR = No Requirement
- M R-8 is required if rigid insulation above or below the roof deck complies with Option A or B in Prescriptive [Table 150.1-A](#). If Option C is used, duct leakage testing is required.
- N For information about other HVAC equipment efficiency requirements, refer to [Chapter 4 of the 2016 Residential Compliance Manual](#).
- O V = rated storage volume of water heater in gallons

For more information

- See Energy Code Ace Quick Reference Sheets: energycodeace.com/content/resources-fact-sheets/
 - Residential Heating & Cooling Equipment Minimum Efficiencies
 - Short Glossary of Terms



This program is funded by California utility customers under the auspices of the California Public Utilities Commission and in support of the California Energy Commission. © 2016 Pacific Gas and Electric Company, San Diego Gas and Electric, Southern California Gas Company and Southern California Edison. All rights reserved, except that this document may be used, copied, and distributed without modification. Neither PG&E, Sempra, nor SCE — nor any of their employees makes any warranty, express or implied; or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any data, information, method, product, policy or process disclosed in this document; or represents that its use will not infringe any privately-owned rights including, but not limited to patents, trademarks or copyrights.