



Permit Number: _____

NRCC-PRC-## (Process) Are the appropriate acceptance forms (NRCA) indicated on the NRCC?		N/A	YES	NO*
PRC-01-F: Compressed Air Systems	Required for all compressed air systems >25 HP	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PRC-02-F: Commercial Kitchen Exhaust	Required for all new and altered kitchen exhaust systems	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PRC-03-F: Parking Garage Exhaust	Required for all enclosed parking garage exhaust systems with a design ventilation low rate of >10,000 cfm	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PRC-04-F: Refrigerated Warehouse Evaporator Fan Motor Controls Acceptance	Refrigerated warehouse evaporator fan motor controls	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PRC-05-F: Refrigerated Warehouse Evaporator Condenser Controls	Refrigerated warehouse evaporator condenser controls	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PRC-06-F: Refrigerated Warehouse Air Cooled Condenser Controls	Refrigerated warehouse air cooled condenser controls	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PRC-07-F: Refrigerated Warehouse Variable Speed Compressors	Refrigerated warehouse variable speed compressors	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PRC-08-F: Refrigerated Warehouse Underslab Heating	Refrigerated warehouse underslab heating	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
NRCC-ELC-01 (Electrical) Are the appropriate sections of the NRCC-ELC-01E completed correctly?				
NRCC-ELC-01E A. Electrical Service Metering	Each newly installed electrical service (in both existing and newly constructed buildings)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
NRCC-ELC-01E B. Disaggregation of Electrical Circuits	Each newly installed switchboard, panel, and motor control center (in both existing and newly constructed buildings).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
NRCC-ELC-01E C. Voltage Drop	Field inspector has discretion to approve the worksheets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
NRCC-ELC-01E D. Circuit Controls for 120-Volt Receptacles	At least one controlled receptacle is installed within 6 feet of each uncontrolled receptacle, or split-wired duplex receptacles are installed, that have one controlled and one uncontrolled receptacle. This applies in all of the following spaces: Private offices, open office areas, reception and lobbies; conference rooms; kitchenettes in office spaces; copy rooms. For hotel and motel guestrooms at least one-half of the 120-volt receptacles in each guest room are controlled receptacles.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

A = Certified Acceptance Tester
 F = Installing Contractor (Field Technician)
 H = HERS Rater

** Items marked "no" must be corrected*

