

What is HERS?

HERS stands for Home Energy Rating System, and is a program developed to address poor construction quality and equipment installation. In the 2016 Building Energy Efficiency Standards (Energy Standards) technologies and systems that trigger HERS verification are considered "HERS measures." These cover HVAC systems, ductwork, ventilation, plumbing and insulation for residential projects, and ductwork for nonresidential projects. In order to verify these HERS measures, certified HERS Raters perform onsite inspections and tests, to ensure proper installation and code compliance.

Type of projects requiring HERS verification:

- Residential, multifamily, and nonresidential (newly constructed buildings, and additions and alterations)
- [New Solar Homes Partnership Program](#) (newly constructed residential buildings)
- Those pursuing a California Whole-House Home Energy Rating

The [Forms Ace tool](#) is useful in determining if any HERS verification measures and forms apply to a specific project or scenario.

Why should I care about HERS?

As a homeowner or building owner, you should expect your building features to be installed as designed and compliant with the Energy Standards. The HERS verification process ensures that the proposed HERS measures are installed and meet code compliance.

Who Does What?

HERS Raters

have been trained and certified by a HERS Provider to verify compliance of HERS measures with California's Energy Standards. They are third-party inspectors who perform field verification and diagnostic testing services for the benefit of the homeowner or building owner to ensure proper measure installation and systems operation.

HERS Providers

are third-party organizations approved by the California Energy Commission to train and certify HERS Raters, and conduct quality assurance reviews to maintain consistency among HERS Raters. Providers also maintain a HERS registry, which contains a database of projects and related compliance documents. Each HERS Provider reports registry data to the Energy Commission on an annual basis so the State can benchmark energy savings measures.

HERS Rater vs. Building Inspector

HERS Raters perform inspections and field verification for HERS measures. These are measures that need more in depth knowledge and usually require special testing equipment to verify the systems installed are working as designed. HERS Raters have been specifically trained and certified to perform this work. HERS Raters are similar to special inspectors and verify compliance on behalf of the building owner.

Building Inspectors

perform inspections for all Building Codes (Structural, Electrical, Plumbing, etc.) during set times throughout construction.

Find a HERS Rater

Contact a HERS Provider listed on the [California Energy Commission's HERS Providers](#) page to find a local HERS Rater. Many HERS Providers have regional search capabilities on their websites.

Compliance Documents

There are several documents that the Building Department will need to verify code compliance. There are three types of Compliance Documents required at different stages of construction. These include:

- Certificate of Compliance (NRCC for nonresidential, and CF1R for residential): Completed by designer, energy consultant, installing contractor or sometimes the owner
- Certificate of Installation (NRCI for nonresidential, and CF2R for residential): Completed by the installing contractor
- Certificate of HERS Verification (NRCV for nonresidential, and CF3R for residential): Completed by the HERS Rater



The [residential compliance documents](#) and the [nonresidential compliance documents](#) are located on the California Energy Commission's website.

As a building owner or homeowner, the compliance documents are yours to keep. These documents are designed to ensure that the installed energy-efficient equipment is in compliance with the Energy Standards and should be passed along with the building's ownership.

How do I register compliance documents?

Registering compliance documentation is a process designed to ensure that equipment is installed in accordance with the Energy Standards requirements listed on the Certificate of Compliance. The Building Department will require a registered CF1R before issuing a permit if HERS measures are required (with limited exceptions). For nonresidential projects, the NRCC is not required to be registered, only the HERS forms (NRCV) are required to be registered.

- **New Construction and Additions:** The registration process is generally initiated by the energy consultant or compliance documentation author. This process will require the owner or contractor to establish an account with the HERS Provider in order to "sign-off" or approve the documentation before a registered CF1R may be printed. This is an important step in the process and should be completed to prevent delays in registration.
- **Alterations:** The compliance documentation for alterations is generally initiated by the installing contractor and does not require the owner to sign-off.

To establish an account with a HERS Provider, go to a provider's website and follow their directions based on your role (home owner, contractor or architect/designer). For security purposes, this process will require you to provide personal identification. Once your account is established, you will have access to either create or sign-off on a project, whichever is applicable.



What do I do after my compliance documents are approved in the HERS Registry?

Once the compliance documents have been approved and signed-off by all responsible parties, they are ready to be printed and submitted to the Building Department. The registered compliance documents will contain a unique registration number, date and time stamp, and name of HERS Provider at the bottom of each page. This tells the Building Department that the documents are registered. If any changes occur to the scope of work, the CF1R will need to be revised, registered, and re-submitted to the Building Department for approval.

Registration Number: thisisnotareal#	Registration Date/Time: 5/5/55 5:55	HERS Provider: HERSRUS
CA Building Energy Efficiency Standards - 2016 Residential Compliance	Report Version: CF1R-04141016-574	Report Generated at: 4/29/2017:9:35:55 PM

When do I need to hire a HERS Rater?

A homeowner or installing contractor will need to hire a HERS Rater when the CF1R or NRCC requires HERS measures. Typically a HERS Rater should be selected at the beginning of construction so they can inform the contractor about when they need to perform inspections and testing.

For new construction and additions, it is important to coordinate with the energy consultant or documentation author when assigning a Rater to the project. This allows the Rater to have access to the registered compliance documentation associated with the project. This is also the case with alterations, but typically the installing contractor will assign the Rater to the project. The cost of HERS Raters varies depending on the HERS measure.

Residential Requirements

Mandatory

The following examples are features that will likely trigger Mandatory HERS verification requirements.

New homes or additions greater than 1,000 ft²

- Triggers the indoor air quality (IAQ) ventilation measure, which requires the installation of a mechanical ventilation system that complies with the airflow rate required by ASHRAE Standard 62.2. A HERS Rater would use airflow measurement tools to verify compliance.

New or altered central HVAC equipment or altered/extended ductwork more than 40ft

- Triggers duct leakage testing to verify minimal duct leakage (<5% for new systems and <15% for altered). This measure ensures your cooling and heating systems are efficiently transferring air to conditioned spaces. This is the most common HERS measure.

New HVAC equipment or replacing existing HVAC systems with all new equipment and all new ductwork

- Triggers air flow and fan watt draw measures, to verify an improved airflow rate of 350 cfm/ton in forced air systems and a reduced fan power draw to 0.58 Watt/cfm. These tests verify motor efficacy and that the duct system has low air flow resistance.

Prescriptive

If your project is using the Prescriptive method and involves one of the following features, you will likely trigger HERS verifications.

New HVAC equipment with AC or altered AC systems in Climate Zones 2, 8-15 (find Climate Zone by zip code or area [here](#))

- Triggers refrigerant charge testing to verify correct refrigerant charge. This will assure proper refrigerant charge of your AC unit.

New ducts in conditioned space

- Triggers visual inspection of duct location and duct testing to verify low leakage to the outside. Duct insulation is required.

Using a central forced air unit (FAU) for mechanical ventilation (central fan integrated ventilation)

- Triggers fan watt draw and airflow testing similar to the mandatory measure process.

Using a zonally controlled forced air unit (FAU), bypass cannot be used

- Triggers visual inspection to confirm that the bypass ducts are not used. Bypass ducts can send heated or cooled air back into the space conditioning equipment, which can cause problems and reduce efficiency.

Whole-House Home Energy Rating

A whole-house home energy rating is a way for homeowners to compare the energy usage of their home to other similar homes and identify additional ways to reduce energy. This rating is performed through a series of energy audits or evaluations. The initial audit assesses the building and identifies potential energy efficiency improvements. It identifies a path for the owner to improve the efficiency of their property.

Once the improvements have been completed, a Whole-House Home Energy Rating is performed. This rating lets homeowners know how their home compares to others and provides an official certificate that shows their energy score on a specific statewide scale.

It is of particular interest if you are considering the sale of your home since the rating will convey the home's relative energy efficiency. A trained and certified HERS Rater can perform the audit and provide the report for a Whole-House Home Energy Rating. For more information, see [approved HERS Providers' websites](#) or the CEC's [Home Energy Rating System Booklet](#).

Performance

If you use the Performance approach to demonstrate project compliance, you will likely need an energy consultant or Certified Energy Analyst (CEA) to analyze the project and complete the compliance documentation. See the California Association of Building Energy Consultants (CABEC) [website](#) for more information on finding a CEA. Common Performance measures that require HERS verification include:

- Quality Insulation Installation (QII)
- Building envelope sealing
- Refrigerant charge or installation of a fault indicator display (FID)
- Ducts in conditioned space
- High SEER/EER
- Verified hot water pipe insulation and parallel piping

For more information on residential HERS measures, see the Energy Code Ace [Quick Reference Sheet for Residential and Nonresidential HERS Measures](#).

Nonresidential Requirements

Table 1 outlines the 2016 Nonresidential HERS Requirements.

HERS Measures	Mandatory 	Prescriptive 	Performance ^A 	Reference Appendices
MECHANICAL				
Duct sealing (maximum leakage)		§140.4(l) §141.0(b)2D §141.0(b)2E		NA1, NA2, RA3.1
Low leakage air handlers			§110.2(f)	RA3.1
PLUMBING				
Multifamily/Hotel & Motel recirculation systems (piping and controls)		§150.1(c)8	X	RA4.4
Multifamily/Hotel & Motel pipe insulation		§150.1(c)8	X	RA4.4

A An "X" indicates "may be taken as a Performance requirement and must be field-verified if taken."

Table 1: Nonresidential HERS Requirements

HVAC Definitions

Entirely New System: All system heating/cooling equipment is replaced and ≥ 75% of the duct material is new.

Altered or Replaced Ducts: When ≥ 75% of the duct system is new or replaced. Existing duct system components (up to 25%) can be reused if they are accessible and can be sealed. Replacement or extension of ductwork over 40 feet is also within this category.

Altered Systems: A system altered by installing or replacing a cooling coil, condenser unit, compressor, refrigerant piping, refrigerant metering device, air handler, or heat exchanger. Replacing other components is considered a repair and not subject to code compliance.

For More Information

Find A...

- HERS Rater:
energy.ca.gov/HERS/providers.html
- Certified Energy Analyst:
cabec.org/find/

California Energy Commission Information & Services

- Energy Standards Hotline: 1-800-772-3300 (Free) or Title24@energy.ca.gov
- Online Resource Center:
energy.ca.gov/title24/orc/
 - The Energy Commission’s main web portal for Energy Standards, including information, documents, and historical information
- Home Energy Rating System (HERS) Program Sub-site:
energy.ca.gov/HERS/
- What is Your Home Energy Rating booklet
energy.ca.gov/HERS/booklet.html
- California Building Climate Zone Map:
energy.ca.gov/maps/renewable/building_climate_zones.html

Additional Resources

- California Association of Building Energy Consultants (CABEC):
cabec.org
 - For information on where to find a Certified Energy Analyst (CEA)
- Energy Code Ace:
EnergyCodeAce.com
 - An online “one-stop-shop” providing free resources and training to help appliance and building industry professionals decode and comply with Title 24, Part 6 and Title 20. The site is administered by California’s investor-owned utilities. Please register with the site and select an industry role for your profile in order to receive messages about all our free offerings!

Of special interest:

- HERS Measures Quick Reference Sheet:
EnergyCodeAce.com/content/resources-fact-sheets/
- Forms Ace:
EnergyCodeAce.com/content/forms-ace/
 - An interactive tool designed to help you determine which Title 24, Part 6 Forms are applicable to your specific project

Please register with the site and select an industry role for your profile in order to receive messages about all our free offerings!



This program is funded by California utility customers under the auspices of the California Public Utilities Commission and in support of the California Energy Commission. © 2016 Pacific Gas and Electric Company, San Diego Gas and Electric, Southern California Gas Company and Southern California Edison. All rights reserved, except that this document may be used, copied, and distributed without modification. Neither PG&E, Sempra, nor SCE — nor any of their employees makes any warranty, express of implied; or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any data, information, method, product, policy or process disclosed in this document; or represents that its use will not infringe any privately-owned rights including, but not limited to patents, trademarks or copyrights.